

KLEA 507 specs

ANALYTE	SPECIFICATION	
Appearance & Colour	Clear & Colourless	
Odour	No Strange Odour	
PURITY	99.5 % min.	
WATER CONTENT	20 ppm max.	
ACIDITY	1 ppm max.	
EVAPORATION RESIDUE	100 ppm max.	
COMPOSITION	HFC-143	HFC-125
	48.50-50.50	51.50-49.50